

LOCAL FIRE AUTHORITY REVIEW

To facilitate the Division of the State Architect's (DSA) approval of the Fire/Life Safety portion of a project, DSA requires Local Fire Authority (LFA) review of certain elements as identified in this form. Use of this form is mandatory for projects that add square footage to a campus or if any item on this form is relevant to the project. For additional information, see [DSA 810 Instructions](#) and [DSA Policy 09-01](#).

PROJECT INFORMATION
School District/Owner:
Project Name/School:
Project Address:

LOCAL FIRE AUTHORITY (LFA)	
LFA Agency Name:	
LFA Reviewer Name:	Title:
Email:	Telephone Number:
I have reviewed and responded to the applicable items for this project as listed below. Note: Only sign this form when it is imaged onto the site plan. A loose form is not acceptable to DSA.	
LFA Reviewer's Signature: _____ Date: _____	
Review Key: "Y" = Complies with LFA requirements "N" = Not approved (complete Section 8) "NA" = Not applicable to the project "NR" = LFA elects not to review	

	Description	Y	N	NA	NR
1	Where an elevator does not meet medical emergency service cab size, per the California Building Code (CBC), use of stairways for emergency rescue and patient transport is acceptable.				
2	Access roads, fire lane markings, pavers and gate entrances are in accordance with Title 19, California Code of Regulations and the California Fire Code, Chapter 5.				
3	Fire hydrant location and distribution complies with the California Fire Code (or see # 4).				
4	Fire hydrant location and distribution complies with NFPA 1142, "Alternate Means." If "NR" is checked, DSA can only approve on-site water storage as an alternate. The signature of the school district official is required to acknowledge the use of alternate means.				
	Signature of School District Official: _____ Date: _____				
	Print the School District Official's Name: _____				
5	The location(s) of the proposed post indicator valve and fire department connection meet the requirements of this jurisdiction.				
6	The location(s) of the detector check valve assembly meet the requirements of this jurisdiction.				
7	Is the project located in a hazard severity zone area? (CBC, Chapter 7A, Section 701A.) <input type="checkbox"/> Yes <input type="checkbox"/> No Check type if "Yes": <input type="checkbox"/> Moderate <input type="checkbox"/> High <input type="checkbox"/> Very High <input type="checkbox"/> WIFA (If one of these boxes is checked, the project design must meet the requirements of Chapter 7A.)				
8	COMMENTS (note deficiencies):				