	DATE:
	TIME:
SERVICE ORGANIZATION	PROPERTY NAME (USER)
Name:	Name:
Address:	Address:
Representative:	Owner Contact:
License No.:	
Telephone:	
MONITORING ENTITY	APPROVING AGENCY
Contact:	Contact:
Telephone:	Telephone:
Monitoring Account Ref. No.:	
TYPE TRANSMISSION	SERVICE
☐ McCulloh	□ Weekly
☐ Multiplex	☐ Monthly
□ Digital	Quarterly
☐ Reverse Priority	Semiannually
□ RF	☐ Annually
Other (Specify)	□ Other (Specify)
Control Unit Manufacturer:	Model No.:
Circuit Styles:	
Number of Circuits:	
Software Rev.:	
	d:
	n Was Revised:
and and they become of cominguitation	- 1.0 1.0 1.0 1.0 1.0 1.0 1.0 1.0 1.0 1.0
ALARM-INIT	TATING DEVICES AND CIRCUIT INFORMATION
Quantity Circuit Styl	e
	Manual Fire Alarm Boxes
	Ion Detectors
	Photo Detectors
	Duct Detectors
	Heat Detectors
	Waterflow Switches
	Supervisory Switches
	Other (Specify):

FIGURE 10.6.2.3 Example of an Inspection and Testing Form.

Quantity	Circuit Style	
		Bells
		Horns
		Chimes
2		Strobes
		Speakers
		Other (Specify):
o. of alarm notification ap	onliance circuits:	other (openly).
	integrity?	
SUPE	ERVISORY SIGNAL-INITIATING	DEVICES AND CIRCUIT INFORMATION
Quantity	Circuit Style	
		Building Temp.
		Site Water Temp.
	4.0	Site Water Level
		Fire Pump Power
		Fire Pump Running
		Fire Pump Auto Position
		Fire Pump or Pump Controller Trouble
		Fire Pump Running
		Generator In Auto Position
		Generator or Controller Trouble
		Switch Transfer
=======================================		Generator Engine Running
		Othor
		Other:
uantity and style of signa	S lling line circuits connected to syste	em (see NFPA 72, Table 6.6.1):
uantity and style of signa Quantity	ling line circuits connected to syste	em (see NFPA 72, Table 6.6.1):
uantity and style of signa Quantity YSTEM POWER SUPPLIE	ling line circuits connected to syste	em (see NFPA 72, Table 6.6.1): Style(s)
uantity and style of signa Quantity YSTEM POWER SUPPLIE (a) Primary (Main):	ling line circuits connected to syste S Nominal Voltage	em (see NFPA 72, Table 6.6.1): Style(s) Amps
uantity and style of signa Quantity YSTEM POWER SUPPLIE (a) Primary (Main): Overcurrent Protect	Lling line circuits connected to syste S Nominal Voltage tion: Type	em (see NFPA 72, Table 6.6.1): Style(s) Amps Amps
uantity and style of signa Quantity YSTEM POWER SUPPLIE (a) Primary (Main): N Overcurrent Protect Location (of Primary	Lling line circuits connected to syste S Nominal Voltage tion: Type y Supply Panelboard):	em (see NFPA 72, Table 6.6.1): Style(s)
uantity and style of signa Quantity YSTEM POWER SUPPLIE (a) Primary (Main): Overcurrent Protect Location (of Primary Disconnecting Mean	Ling line circuits connected to systems S Nominal Voltage tion: Type y Supply Panelboard): ns Location:	em (see NFPA 72, Table 6.6.1): Style(s) Amps Amps
uantity and style of signa Quantity YSTEM POWER SUPPLIE (a) Primary (Main): Overcurrent Protect Location (of Primary Disconnecting Mean (b) Secondary (Standby	Ling line circuits connected to systems Solution: Type	em (see NFPA 72, Table 6.6.1): Style(s) Amps Amps Amps
uantity and style of signa Quantity YSTEM POWER SUPPLIE (a) Primary (Main): Overcurrent Protect Location (of Primary Disconnecting Mean (b) Secondary (Standby	Iling line circuits connected to systems Solution: Type	em (see NFPA 72, Table 6.6.1): Style(s) Amps Amps tery: Amp-Hr. Rating
uantity and style of signa Quantity YSTEM POWER SUPPLIE (a) Primary (Main): N Overcurrent Protect Location (of Primary Disconnecting Mean (b) Secondary (Standby	Iling line circuits connected to systems Solution: Type	em (see NFPA 72, Table 6.6.1): Style(s) Amps Amps tery: Amp-Hr. Rating 60
ystem Power Supplie (a) Primary (Main): Novercurrent Protect Location (of Primary Disconnecting Mean (b) Secondary (Standby Calculated capacity	ES Nominal Voltage tion: Type y Supply Panelboard): ns Location: /): Storage Bat to operate system, in hours:	tery: Amp-Hr. Rating 60 Engine-driven generator dedicated to fire alarm syste
uantity and style of signa Quantity YSTEM POWER SUPPLIE (a) Primary (Main): Novercurrent Protect Location (of Primary Disconnecting Mean (b) Secondary (Standby Calculated capacity Location of fuel store	ES Nominal Voltage tion: Type y Supply Panelboard): ns Location: /): Storage Bat to operate system, in hours:	tery: Amp-Hr. Rating 60 Engine-driven generator dedicated to fire alarm syste
uantity and style of signa Quantity YSTEM POWER SUPPLIE (a) Primary (Main): Novercurrent Protect Location (of Primary Disconnecting Mean (b) Secondary (Standby Calculated capacity Location of fuel story YPE BATTERY	ES Nominal Voltage tion: Type y Supply Panelboard): ns Location: /): Storage Bat to operate system, in hours:	tery: Amp-Hr. Rating 60 Engine-driven generator dedicated to fire alarm syste
uantity and style of signa Quantity YSTEM POWER SUPPLIE (a) Primary (Main): Novercurrent Protect Location (of Primary Disconnecting Mean (b) Secondary (Standby Calculated capacity Location of fuel story YPE BATTERY Dry Cell	ES Nominal Voltage tion: Type y Supply Panelboard): ns Location: /): Storage Bat to operate system, in hours:	tery: Amp-Hr. Rating 60 Engine-driven generator dedicated to fire alarm syste
uantity and style of signa Quantity YSTEM POWER SUPPLIE (a) Primary (Main): Novercurrent Protect Location (of Primary Disconnecting Mean (b) Secondary (Standby Calculated capacity Location of fuel story YPE BATTERY Dry Cell Nickel-Cadmium	ES Nominal Voltage tion: Type y Supply Panelboard): ns Location: /): Storage Bat to operate system, in hours:	em (see NFPA 72, Table 6.6.1): Style(s) Amps Amps tery: Amp-Hr. Rating 60 24 60 Engine-driven generator dedicated to fire alarm syste
uantity and style of signa Quantity YSTEM POWER SUPPLIE (a) Primary (Main): N Overcurrent Protect Location (of Primary Disconnecting Mean (b) Secondary (Standby Calculated capacity Location of fuel stor YPE BATTERY Dry Cell Nickel-Cadmium Sealed Lead-Acid	ES Nominal Voltage tion: Type y Supply Panelboard): ns Location: /): Storage Bat to operate system, in hours:	tery: Amp-Hr. Rating 60 Engine-driven generator dedicated to fire alarm syste
uantity and style of signa Quantity YSTEM POWER SUPPLIE (a) Primary (Main): Novercurrent Protect Location (of Primary Disconnecting Mean (b) Secondary (Standby Calculated capacity Location of fuel story YPE BATTERY Dry Cell Nickel-Cadmium Sealed Lead-Acid Lead-Acid	ES Nominal Voltage tion: Type y Supply Panelboard): ns Location: /): Storage Bat to operate system, in hours:	tery: Amp-Hr. Rating 60 Engine-driven generator dedicated to fire alarm syste
uantity and style of signa Quantity YSTEM POWER SUPPLIE (a) Primary (Main): Novercurrent Protect Location (of Primary Disconnecting Mean (b) Secondary (Standby Calculated capacity Location of fuel story YPE BATTERY Dry Cell Nickel-Cadmium Sealed Lead-Acid Lead-Acid Other (Specify):	Nominal Voltage	em (see NFPA 72, Table 6.6.1): Style(s) Amps Amps tery: Amp-Hr. Rating 24 Engine-driven generator dedicated to fire alarm syste
uantity and style of signa Quantity YSTEM POWER SUPPLIE (a) Primary (Main): Novercurrent Protect Location (of Primary Disconnecting Mean (b) Secondary (Standby Calculated capacity Location of fuel story YPE BATTERY Dry Cell Nickel-Cadmium Sealed Lead-Acid Lead-Acid Other (Specify): (c) Emergency or stand	SS Nominal Voltage	em (see NFPA 72, Table 6.6.1): Style(s) Amps Amps tery: Amp-Hr. Rating 60 Engine-driven generator dedicated to fire alarm syste
Quantity and style of signa Quantity	Is Nominal Voltage	em (see NFPA 72, Table 6.6.1): Style(s) Amps Amps tery: Amp-Hr. Rating 60
Quantity	Is Nominal Voltage	em (see NFPA 72, Table 6.6.1): Style(s) Amps Amps tery: Amp-Hr. Rating 24 Engine-driven generator dedicated to fire alarm syste mary power supply, instead of using a secondary power supply: A 70, Article 700 n NFPA 70, Article 701
Quantity and style of signa Quantity	Is Nominal Voltage	em (see NFPA 72, Table 6.6.1): Style(s) Amps

FIGURE 10.6.2.3 Continued

			PRIOR TO AN	IY TESTING			
NOTIFICATIONS	ARE MADE		Yes	No	Who		Time
Monitoring Entit	v						
Building Occupar							
Building Manage						-	
Other (Specify)			5	5	5 	=	
AHJ Notified of A	any Impairments		<u> </u>			-	
		SYS	STEM TESTS AN	ID INSPECTIONS			
TYPE			Visual	Functional	Con	mments	
Control Unit							
Interface Equipm	ent			٥			
Lamps/LEDS				a	57		
Fuses							
Primary Power S	upply		<u> </u>	5	is and the second		
Trouble Signals	1.2.0		5	5	-		
Disconnect Switch	hes		ā.	ā	2		
Ground-Fault Mo			5	5	id ia		
SECONDARY PO	WER						
TYPE			Visual	Functional	Cor	mments	
Battery Condition	1						
Load Voltage					S-		
Discharge Test					<u> </u>		
Charger Test					ā		
Specific Gravity				-	ā		
TRANSIENT SUP	PRESSORS				5		
REMOTE ANNUN	ICIATORS						
NOTIFICATION A	PPLIANCES						
Audible							
Visible					Ş .		
Speakers					2		
Voice Clarity			ST.	٥	a a		
	INITIAT	ING AND SU	IPERVISORY DE	EVICE TESTS AND	INSPECTIONS		
Loc. & S/N	Device Type	Visual Check	Functional Test	Factory Setting	Measured Setting	Pass	Fail
	50 M. B. (376)			vas=4990000 = 5.2			
		5	_			5	
		<u> </u>	ā		: 	5	_
=======================================		<u> </u>	ō	-	2	5	5
		ä	5		6 S	<u> </u>	<u> </u>
		5	5			<u> </u>	_
			_	- 1	-	_	_
Comments:							

FIGURE 10.6.2.3 Continued

EMERGENCY COMMUNICATIONS EQUIPMENT		Visual	Functional	Comments
Phone Set				
Phone Jacks				
Off-Hook Indicator				7
Amplifier(s)			J	-
Tone Generator(s)		ū		(2) (C
Call-in Signal			٦	:
System Performance			9	6
		Visual	Device Operation	Simulated Operation
INTERFACE EQUIPMENT		V ISUUI	operation	operation
(Specify)				
(Specify)			٦	
(Specify)				
SPECIAL HAZARD SYSTEMS				
(Specify)			J	
(Specify)		ū		
(Specify)			ت	
Special Procedures:			100.47	100.00
SUPERVISING STATION MONITORING			Time	Comments
SUPERVISING STATION MONITORING Alarm Signal Alarm Restoration Trouble Signal Supervisory Signal	Yes	No - - -	Time	Comments
SUPERVISING STATION MONITORING Alarm Signal Alarm Restoration Trouble Signal Supervisory Signal	Yes	No	Time	Comments
SUPERVISING STATION MONITORING Alarm Signal Alarm Restoration Trouble Signal Supervisory Signal Supervisory Restoration NOTIFICATIONS THAT TESTING IS COMPLETE	Yes	No	Time	Comments
SUPERVISING STATION MONITORING Alarm Signal Alarm Restoration Trouble Signal Supervisory Signal Supervisory Restoration NOTIFICATIONS THAT TESTING IS COMPLETE Building Management	Yes	No 		
SUPERVISING STATION MONITORING Alarm Signal Alarm Restoration Trouble Signal Supervisory Signal Supervisory Restoration NOTIFICATIONS THAT TESTING IS COMPLETE Building Management Monitoring Agency	Yes	No - - - - - -		
SUPERVISING STATION MONITORING Alarm Signal Alarm Restoration Trouble Signal Supervisory Signal Supervisory Restoration NOTIFICATIONS THAT TESTING IS COMPLETE Building Management Monitoring Agency Building Occupants	Yes	No O No O O O O O O O O O O O O O		
SUPERVISING STATION MONITORING Alarm Signal Alarm Restoration Trouble Signal Supervisory Signal Supervisory Restoration NOTIFICATIONS THAT TESTING IS COMPLETE Building Management Monitoring Agency	Yes	No O No No		
SUPERVISING STATION MONITORING Alarm Signal Alarm Restoration Trouble Signal Supervisory Signal Supervisory Restoration NOTIFICATIONS THAT TESTING IS COMPLETE Building Management Monitoring Agency Building Occupants Other (Specify)	Yes	No O No O O O O O O O O O O O O O	Who	
SUPERVISING STATION MONITORING Alarm Signal Alarm Restoration Trouble Signal Supervisory Signal Supervisory Restoration NOTIFICATIONS THAT TESTING IS COMPLETE Building Management Monitoring Agency Building Occupants Other (Specify) The following did not operate correctly:	Yes	No O	Who	
SUPERVISING STATION MONITORING Alarm Signal Alarm Restoration Trouble Signal Supervisory Signal Supervisory Restoration NOTIFICATIONS THAT TESTING IS COMPLETE Building Management Monitoring Agency Building Occupants Other (Specify)	Yes	No O	Who	
SUPERVISING STATION MONITORING Alarm Signal Alarm Restoration Trouble Signal Supervisory Signal Supervisory Restoration NOTIFICATIONS THAT TESTING IS COMPLETE Building Management Monitoring Agency Building Occupants Other (Specify) The following did not operate correctly: System restored to normal operation: Date: THIS TESTING WAS PERFORMED IN ACCORDANCE	Yes Yes U U U E WITH APP	No No Time:	Who	Time
SUPERVISING STATION MONITORING Alarm Signal Alarm Restoration Trouble Signal Supervisory Signal Supervisory Restoration NOTIFICATIONS THAT TESTING IS COMPLETE Building Management Monitoring Agency Building Occupants Other (Specify) The following did not operate correctly: System restored to normal operation: Date: THIS TESTING WAS PERFORMED IN ACCORDANCE	Yes Yes U U U U U U U U U U U U U U U U U U	No	Who	Time
SUPERVISING STATION MONITORING Alarm Signal Alarm Restoration Trouble Signal Supervisory Signal Supervisory Restoration NOTIFICATIONS THAT TESTING IS COMPLETE Building Management Monitoring Agency Building Occupants Other (Specify) The following did not operate correctly: System restored to normal operation: Date: THIS TESTING WAS PERFORMED IN ACCORDANCE	Yes Yes U U U U U U U U U U U U U U U U U U	No	Who	Time
SUPERVISING STATION MONITORING Alarm Signal Alarm Restoration Trouble Signal Supervisory Signal Supervisory Restoration NOTIFICATIONS THAT TESTING IS COMPLETE Building Management Monitoring Agency Building Occupants Other (Specify) The following did not operate correctly:	Yes	No	Who	Time
SUPERVISING STATION MONITORING Alarm Signal Alarm Restoration Trouble Signal Supervisory Signal Supervisory Restoration NOTIFICATIONS THAT TESTING IS COMPLETE Building Management Monitoring Agency Building Occupants Other (Specify) The following did not operate correctly:	Yes Yes With App	No	Who	Time

FIGURE 10.6.2.3 Continued